



MISSOURI SOCIETY FOR HEALTHCARE ENGINEERING
Member of ASHE since 1972
mosheonline.org

MOSHE: Advocacy Committee Update



Top 10 Joint Commission Findings for Hospitals in 2018, Including 1460 Surveys.

- 1) LS.02.01.35 - 89%
Maintaining system for extinguishing fire
 - Confirm there are no issues on the fire alarm
 - Fire Sprinklers are damaged
- 2) EC.02.05.01 - 79%
Risks associated with Utility Systems
 - Written inventory of all operating components of utility system
- 3) EC.02.06.01 - 74%
Maintain safe, functional environment
 - Furniture kept in good repair
- 4) LS.02.01.30 – 73%
Protect individuals from the hazard of fire and smoke
 - Hazardous Stage
 - Shaft wall construction
- 5) IC.02.02.01 – 71%
Reduces the risk of infection associated with Medical equipment, devices, and supplies
- 6) LS.02.01.10 – 71%
Building and Fire protection features are designed and maintain to minimize effects of fire and smoke
 - Smoke wall
 - Separate occupancy
- 7) LS.02.01.20 – 67%
Integrity of means of egress
 - Exit paths
 - Exit enclosure
- 8) EC.02.05.05 – 65%
Inspect, test, and maintains Utility Systems
 - Maintain high and low risk Utilities Inventory list
- 9) EC.02.02.01 – 62%
Risks related to Hazardous material and waste
 - Written inventory of hazardous material and waste that is used, stored, and generated
- 10) EC.02.05.09 – 62%
Maintains medical gas and vacuum system
 - Oxygen connection
 - Policy of tank storage

If you have any questions, please contact MOSHE's Advocacy Committee.

Advocacy Committee Chair

Greg Hrbacek
Healthcare Life Safety Specialist, Facility Operations
St. Louis Children's Hospital
1 Children's Place
St. Louis, MO 63110-1002
greg.hrbacek@bjc.org

Advocacy Committee Co-Chair

Alexander F. Zivnuska
Sr. Project Consultant
Code Consultants, Inc.
2043 Woodland Pkwy, Suite 300
St. Louis, MO 63146-4235
alexz@codeconsultants.com